CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

TIRE ENGINEERING - BOILDING WATERIALS LISTING FR

LISTING SERVICE

LISTING No. 7120-1496:153 Page 1 of 1

CATEGORY: Annunciators

LISTEE: Firecom Inc., 39-27 59th Street, Woodside, NY 11377

Contact: Howard Kogen (718) 899-6100

DESIGN: Models FCSAN-16, FCSAN-16RC, FCPDM-16, FCRAN, FCRAN-RC, FCRAN2 and

FCRAN2-RC remote annunciators. Refer to listee's data sheet for additional detailed

product description and operational considerations.

RATING: 17.6 - 30 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as remote annunciators for use with listee's separately listed compatible Models

FC610 fire alarm control unit (CSFM Listing No. 7165-1496:156).

XLF: 7120-1288:149

09-29-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: APRIL 22, 2002 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager